

# City of Robinson

## WWTF



Telephone: (618) 544-5110 Fax: (618) 544-4300



ROBINSON, ILLINOIS 62454

E.H. Baare Corporation  
500 Heath Toffee Avenue  
Robinson, Illinois 62454

November 15, 2021

Attention: Mr. Travis Crumrin

RECEIVED NOV 1 2021

Subject: Notice of Violation  
Permit #: RB20  
Ordinance #: 2020-0-30

Mr. Crumrin:

You reported to the City on 11/12/2021 that your Local Limits compliance re-testing revealed a Phosphorus level of 22.5 mg/L and a Zinc level of 1.83 mg/L. These two levels are above the limits set forth as Local Limits in Permit Number RB20. The Phosphorus limit is 10 mg/L and Zinc is 0.96 mg/L.

### Interim Conditions:

1. E.H. Baare shall take appropriate steps necessary to keep the discharge levels of these constituents below their respective limits.
2. E.H. Baare shall retest within 5 days and make the results of the tests available to the City of Robinson as soon as you receive them.
3. Any future discharges from E.H. Baare that show non-compliance shall be subject to fines and further enforcement action.
4. **E.H. Baare shall make a payment of one hundred dollars (\$ 100.00) to the City of Robinson within 30 days of the receipt of this notice.** The amount shall be paid by certified check or money order, payable to the City of Robinson Wastewater Treatment Facilities, P.O. Box 188, Robinson, Illinois 62454. Please enclose a copy of this NOV with payment.

If you have any questions concerning this notice of violation of the City of Robinson Industrial Pretreatment Program, please feel free to contact me at (618) 562-0040.

Sincerely,

**CITY OF ROBINSON**

*Lawrence E. Quick*  
Lawrence E. Quick  
Superintendent of Public Works

NOV 29 2021

pd

cc: Mayor Pethtel  
WWTF Committee  
City Clerk  
file